



# ORANGE COUNTY WATER DISTRICT

18700 Ward Street  
Fountain Valley, California 92708

## ADDENDUM NO.1 REQUEST FOR QUOTES (IFQ-25-001) MONITORING WELL FVM-1 VAULT REPLACEMENT Date of Addendum:12/31/2025

This addendum serves as written notice of the following corrections, clarifications, additions and/or deletions to any and all copies of the Request for Quote for MONITORING WELL FVM-1 VAULT REPLACEMENT. The original Request for Quote (IFQ) Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the IFQ. Proposer shall take this Addendum into consideration when preparing and submitting its Proposal.

The proposer shall execute the acknowledgment form at the end of this addendum and shall attach it with proposer's submitted proposal. **Failure to acknowledge receipt of all Addenda may result in rejection of your quote**

---

### 1. Q&A Table

a. Please refer to Attachment A-1 of this Addendum No.1 for the QA Table.

### 2. The following revisions are made to the IFQ (text in red to be added to the IFQ):

#### 5.1 Minimum Qualifications

The selected Contractor is required to have at minimum the following qualifications:

1. Class C contractor's license or **General Engineering A License**
2. Previous valve vault replacement experience

# **ATTACHMENT A-1**

## **Q & A Table**

Q&A Table for Monitoirng Well FVM-1 Vault Replacement

No.	QUESTIONS	ANSWERS
1	To extend the 4" casing pipe by 2ft no problem is there any NDT requirements nothing was listed such as X-ray of the weld etc.	There are no NDT requirements.
2	Also, per the picture and scope we are to protect the 1.75 PVC liner which has a cap on it. well once the 2ft extension is added can the PVC be lifted to accommodate the change in elevation or will it also need to be modified?	OCWD staff will extend the 1.75-inch PVC liner prior to extending the 4-inch steel casing. The contractor will be asked to provide a heat shield to protect the PVC during welding of the steel pipe. There is no specific requirement for the heat shield, just something to reduce heat while welding.
3	Will you accept an General engineering A lic you have C listed. Typically they accept an A	We will accept a General Engineering A License

---

END OF ADDENDUM

---

**MANDATORY FORM**

ACKNOWLEDGE RECEIPT OF ADDENDUM NO.1

**REQUEST FOR QUOTE  
MONITORING WELL FVM-1 VAULT REPLACEMENT  
(IFQ-25-001)**

**12/31/2025**

Proposer shall acknowledge receipt of this addendum by detaching, signing and attaching to his/her quote, one (1) copy of this sheet.

I, \_\_\_\_\_

Name of Proposer, Company Name

---

Address, City, State, Zip

Hereby acknowledge receipt of Addendum No.1 to the **Request for Quote MONITORING WELL FVM-1 VAULT REPLACEMENT** and have considered these revisions in the preparation of my quote. This addendum, consisting of this acknowledgement, shall become a part of any contract made pursuant thereto.

---

Proposer's Signature

---

Printed Proposer's Name

---

Date